



Eugene Gallagher
The Minserve Group Pty Ltd

**INFORMED SELECTION OF THE
CHPP WASTE DISPOSAL SYSTEM**



Introduction


- > **Waste Disposal Options Considered**
- > **Production Scenarios Considered**
- > **Methodology & Assumptions**
- > **Results**
- > **Conclusions**
- > **Acknowledgements**




Options considered

- 1. Separate rejects and tailings disposal**
- 2. Conventional hydraulic co-disposal**
- 3. Dense phase co-disposal using fines recycle**
- 4. Combined disposal of rejects and filtered tailings**
- 5. Combined disposal of rejects and high intensity flocculated tailings**

Separate rejects and tailings disposal



Conventional hydraulic co-disposal




ITEMS LIST

- 1 Thickener Conventional Type
- 2 Thickener Underflow Pump
- 3 Clarified Water Tank
- 4 Clarified Water Pumps
- 5 Rejects Conveyor(s)
- 6 Rejects Collection Hopper/Bin
- 7 Belt Weigher
- 8 Belt Feeder
- 9 Co-disposal Pump Hopper
- 10 Co-disposal Pumps
- 11 Co-disposal Pumps
- 12 Rejects Emplacement
- 13 Return Water Collection Dam
- 14 Return Water Pump


Ac09m002.cdr

Combined disposal of rejects with filtered fines



Ac09m002.cdr

Combined disposal of rejects with flocculated fines



Ac09m002.cdr

Production Scenarios Considered

CASE A - Untreated Fines

Parameter	Units	CASE A1	CASE A2
Plant Feed	t/a ad	2,500,000	10,000,000
Operating Time	h/a	7,000	7,000
Coarse/fine reject sizing	mm	0.25	0.25
Coarse Fraction	%ROM	85.0%	85.0%
Coarse Yield	%ad	77.6%	77.6%
Coarse Rejects Rate	t/a	475,000	1,900,000
Fines Yield	%ad	0.0%	0.0%
Fines Rejects Rate	t/a	375,000	1,500,000
Total Yield	%ad	66.0%	66.0%

CASE B - Untreated Fines

Parameter	Units	CASE B1	CASE B2
Plant Feed	t/a ad	2,500,000	10,000,000
Operating Time	h/a	7,000	7,000
Coarse/fine reject sizing	mm	0.25	0.25
Coarse Fraction	%ROM	85.0%	85.0%
Coarse Yield	%ad	77.6%	77.6%
Coarse Rejects Rate	t/a	475,000	1,900,000
Fines Yield	%ad	60.0%	60.0%
Fines Rejects Rate	t/a	150,000	600,000
Total Yield	%ad	75.0%	75.0%



Methodology & Assumptions

> Other Considerations

- Distance between CHPP and emplacement area (1.5km or 5km)
- Emplacement above ground or in pit


> Selected Scenario

- Base Case A1
- 2.5Mtpa ROM
- Untreated fines
- 1.5km from CHPP
- Emplacement above ground


Attributes of Waste Disposal Options

Corporate Capital	Natural Capital	Human Capital
Production Security	Resource Use	Workforce
	Water	Safety and Health
	Fuels	Well-being
	Power	
Licence to Operate	Operating Emissions	Community
	To Water	Safety and Health
	Noise and Dust	Well-being
	Greenhouse Gases	
Net Present Value	Legacy	
Capex	Land Capability	
Opex	On-going Emissions	


Sustainable Analysis – All Attributes








Sustainable Analysis – Natural Capital



Sustainable Analysis – Corporate Capital



Operating Cost Breakdown





Conclusions

> Lessons:

- Cost analysis alone does not provide all the information needed to select the most suitable waste disposal system.
- Ranking against a broad range of sustainability criteria provides a more complete picture of the standing of the various systems.

> Messages:

- Detailed examination of costs, benefits and disadvantages can help to optimise new and existing waste disposal systems.
- No system for disposal of CHPP waste is best for all situations. Each has strengths and weaknesses that will affect its suitability to a particular project.
- The study established broad guidelines for system suitability but site-specific design and costing is still necessary.

> Issues:

- In general, operating mines do not always keep good records of costs associated with management of waste disposal.
- Wide variations in conditions and costs between different mine sites meant that it was not feasible to cover all combinations.



Acknowledgements

- > This work was undertaken under ACARP Project C15063 of the Australian Coal Association Research Program and the authors would like to thank ACARP for their support
- > The support from industry is also greatly appreciated especially from Anglo Coal and Alcan Engineering
- > Other contributions are also gratefully acknowledged:
 - SOTA Analysis and co-authoring by Dr Sue Henderson
 - Pumping calculations by Mr Stuart Whitton (Mechanical Advantage)
 - Cost modelling assistance by Dr Jiangang Xu (Gallagher Consulting Services Pty Ltd)